Emergency Shower/Eyewash/Drench Hose Activation log

\square Shower Station	☐ Eyewash Station	☐ Drench Hose
Building:		Room:

			, ,			
Date	Initials	Operational?		Date	Initials	Operational?
		-				-
			-			
			-			
			=			
			-			
			-			
			= -			
			-			
			-			
			-			
			-			
			-			
			-			
			-			
			-			
			_			
			_			
			-			

A weekly activation of emergency flushing stations listed above is required per the American National Standards Institute (ANSI) Z358.1 Standard. Weekly activation should be ~30 seconds in duration.